

**ADDENDUM NO. 1**  
**4<sup>th</sup> Street Water Main Replacements Between 12<sup>th</sup> Avenue East And 16<sup>th</sup> Avenue East**  
**City of Duluth**  
**Bid No. 15-0242, Project No. 1378**  
**Bid Opening: 2:00 PM, May 20, 2015**

**NOTICE:**

The addendum is issued to modify, explain or correct the original drawings, specifications and/or previous addendums and is hereby made a part of the Contract Documents. Please attach this Addendum to the specifications in your possession and note receipt of this Addendum on the Request for Bid. The Bid date remains unchanged.

**DRAWINGS**

SHEET 38 OF 43, PIPE BURST PLAN & PROFILE

**ADD**, the following note; "At Station 7+20, reconnect the existing 12" blow-off line".

SHEET 40 OF 38, CIPP PLAN & PROFILE

**ADD** the following note; "At station 7+70, reconnect the existing 12" blow-off line".

**INVITATION TO BID**

In the second paragraph, **REPLACE**: "211A" with "106A".

**SPECIFICATIONS**

SP-20 (2504) PIPE BURST 12" CI TO 12" HDPE

SP-20.4 INSERTION AND RECEIVING EXCAVATIONS

**ADD** the following to paragraph A; "The Contractor will be required to excavate and reconnect the existing 12" blow-off line.

SP-22 (2504) 24" CIPP WATER MAIN RENOVATION

SP-22.4 QUALIFICATIONS

CIPP Installer Contact Information: Mitchel Hoeft, Insituform Technologies, USA, LLC, 651-253-0236 and Chris Van Wormer, Fer-Pal Construction USA, LLC, 734-624-5321.

SP-22.11 TEMPORARY WATER SERVICE

**DELETE** the paragraph and **REPLACE** with; "Temporary water not needed".

SP22.12 INSTALLATION

SP.22.12 (A) EXCAVATION OF INSERTION/EXTRACTION PITS

**ADD** the following to the first paragraph; "The Contractor will be required to excavate and reconnect the 12" blow-off line.

**END OF ADDENDUM**